



Abstract Collection

R Andika Putra Dwijayanto, Fitria Miftasani, Andang Widi Harto, *Transmutation of Transuranic Elements as Solid Coating in Molten Salt Reactor Fuel Channel.*, Tri Dasa Mega, 25 (3), 91.

The accumulation of spent nuclear fuel (SNF) is presently considered a hindrance to the massive deployment of nuclear power plants, especially regarding the transuranic (TRU) elements. Eliminating TRU through transmutation is one of the most feasible alternatives as a technical solution to solve the issue. This study explores the possibility of TRU transmutation using a molten salt reactor (MSR) in a heterogeneous configuration, where a solid TRU is coated inside the fuel channel filled with liquid salt fuel. Such a configuration is proposed to allow higher TRU loading into the fluoride salt mixture without compromising the safety of the reactor. TRU coating was applied in consecutively outward radial fuel channel layers with coating thicknesses of 2.5 mm and 5 mm. The calculation was performed using MCNP6.2 radiation transport code and ENDF/B-VII.0 neutron cross-section library. From the results, TRU coating with a smaller thickness and positioned closer to the centre of the core exhibits higher transmutation efficiency due to exposure to the higher neutron flux. The highest transmutation efficiency was achieved at 67.93% after 160 days of burnup. This shows a potential of achieving highly efficient TRU using heterogeneous configuration in MSR core.

Keywords: *Transmutation, Transuranic element, Molten Salt Reactor, MCNP6.2.*

Gusti Atika Urfa, Totok Wianto, Tetti Novalina Manik, Amar Vijai Nasrulloh., *Study of Alternative Shielding Material for Gamma Radiation using Monte Carlo Simulation.*, Tri Dasa Mega, 25 (3), 101.

Lead is the most commonly used material for radiation shielding, even though it has toxic properties. This study aims to identify alternative, lead-free, and non-toxic materials for gamma radiation shielding using Monte Carlo simulations. Bismuth Oxide (Bi₂O₃), Barium Oxide (BaO), Tungsten Trioxide (WO₃), Tungsten Dioxide (WO₂), and Molybdenum Trioxide (MoO₃) were selected as potential substitutes for lead. Pure lead (Pb) and Lead Oxide (PbO) were used for comparison.

The simulations were performed using Particle Heavy Ion Tracking System (PHITS) software, with a gamma energy of 662 keV. The result of the simulation shows that the linear attenuation coefficient values for Pb and PbO were 0.902 mm⁻¹ and 0.74 mm⁻¹ respectively. Meanwhile, the simulation results of those simulated materials that are closest to Pb and PbO are Bi₂O₃ and WO₂ with an attenuation coefficient of 0.71 mm⁻¹. This simulation shows that for non-lead materials, Bi₂O₃ and WO₂ have potential as alternatives for non-lead radiation shielding.

Keywords: *Shielding material, Radiation, Lead, Non-Lead, PHITS, Monte Carlo.*

Muksin Aji Setiawan, Sigit Santoso, Tulis Jojok Suryono, Kiswanta, Anik Purwaningsih, Restu Maerani, Adhika Enggar Pamungkas, Dian Fitri Atmoko, Dhanu Dwiardhika., *An Ergonomic Approach in Designing Nuclear Reactor Simulator Console for Local Operator.*, Tri Dasa Mega, 25 (3), 107.

The construction of a Nuclear Power Plant (NPP) using Small Modular Reactor (SMR) technology is an interesting scheme to support Net-Zero Carbon Emission. The SMR design is an advanced generation reactor with high safety and utilization features, especially for the electricity needed and industry. Its modular size can also be applied to remote areas with lower construction costs compared to other types of power plants. Considering the geographical location and territory of Indonesia, which is an archipelagic country, this type of reactor is suitable for application in Indonesia. To ensure the safety and increase in mastery of the technology, it is necessary to create a simulator to support this program. However, specific regulations governing human-machine interactions (HMI) that cover nuclear reactor simulators are not yet available in Indonesia. This research reviews the US regulations regarding the design of reactor main control rooms, offering options for Indonesian operators by considering anthropometric and ergonomic aspects. In conclusion, the research presents a set of recommendations for developing an appropriate simulator based on these factors.

Keywords: Nuclear Power Plant, Small Modular Reactor, Simulator, Human-Machine Interaction.

Tulis Jojok Suryono, Sigit Santoso, Restu Maerani, Sudarno, Pandhu Ardita Dharma Pratama., *The Development Process of Human Machine Interface of Plant Protection System of a Small Modular Reactor.*, Tri Dasa Mega, 25 (3), 117.

The Plant Protection System (PPS), which consists of Reactor Protection Systems (RPS) and Engineered Safety Actuated Systems (ESFAS), is one of the most important safety systems in nuclear reactors, including Small Modular Reactors (SMRs). The RPS generates a signal to trip the reactor if the measured reactor parameters exceed the trip setpoint, and then the ESFAS is actuated to mitigate the consequences of the accident by minimizing fuel damage and radioactivity release into the environment. Therefore, a comprehensive Human-Machine Interface (HMI) is essential for monitoring and controlling the PPS to ensure its reliability and enhance the operators' situational awareness. This study discusses the development process of the HMI for the digital PPS of an SMR. In this study, various standards, guidance, and design criteria for PPS and HMI are incorporated and applied to ensure that the proposed design meets the required level of reliability. In the first stage, the proposed design is intended to assess the functionality and reliability of the PPS. Moreover, in the future, it will play an essential role in the design phase of the HMI for the PPS of an SMR in Indonesia

Keywords: Plant protection system, Human-machine interface, Experimental power reactor, Safety Functionality.

Muhammad Subhan, Tresna Priyana Soemardi, Topan Setiadipura, Farisy Yogatama Sulisty, Hana Subhiyah., *The Study of Multi-axial Loading and Damage to the Structure and Materials in the PWR Steam Generator of Nuclear Reactor.*, Tri Dasa Mega, 25 (3), 125.

In Pressurized Water Reactor (PWR) Nuclear Power Plants (NPPs), the steam generator is crucial for transferring heat from the primary to secondary cooling systems, vital for steam production to drive turbines, and central to nuclear power safety. This study explores recent research on multi-axial loading, structural integrity, and material durability in PWR steam generators, shedding light on key factors affecting these systems. Common corrosion-related degradation in steam generators often arises from design, material, and water chemistry factors. However, the shift to All Volatile Treatment (AVT), the development of advanced material alloys, and enhanced water quality control in primary and secondary systems have significantly reduced instances of steam generator degradation. These findings promise to enhance the reliability and safety of steam generators in future nuclear applications.

Keywords: Nuclear Reactor, Steam Generator, Pressurize Water Reactor (PWR). Multi-axial loading, Material durability, Structure integrity.



Keywords Index

A

Accumulation, 91
Alternatives, 91, 101
Attenuation, 101
Anthropometric, 107
Approach, 107
Appropriate, 107
Archipelagic, 107
Areas, 107
Accident, 117
Actuated, 117
Advanced, 125
Application, 125
Axial, 125

B

Burnup, 91
Barium, 101
BiO₃, 101
Bi₂O₃, 101
Bismut, 101
Boiling, 99
Boron, 117

C

Calculation, 91
Channel, 91
Coated, 91
Configuration, 91
Considered, 91
Core, 91
Cross-section, 91
Carlo, 101
Coefficient, 101
Carbon, 107
Considering, 107
Console, 107
Construction, 107
Conclusion, 117
Create, 117
Consequences, 117
Cooling, 125

D

Dioxide, 101
Designing, 107
Development, 117
Damage, 125
Degradation, 125

E

Elements, 91
Eliminating, 91
ENDFVIII.0, 91
Explores, 91
Emission, 107
Electricity, 107
Ergonomic, 107
ESFAS, 107
Estimate, 107
Enhance, 117
Essential, 117
Exceed, 117
Engineered, 117

F

Feasible, 91
Fluoride, 91
Fuel, 91
Flux, 91
Factor, 107, 125

G

Gamma, 101
Geographical, 107
Generation, 107
Governing, 107
Guidance, 117
Generator, 125

H

Hindrance, 91
Higher, 91
heterogeneous, 91
Heavy, 101
Human, 101, 107
Heat, 125

I

Industry, 101
Ion, 101
Indonesia, 107, 117
Important, 107
Intended, 117

K

Key, 125

L

Layers, 91
Liquid, 91
Loading, 91, 125
Lead, 101
Lower, 101
Location, 107

M

Molten, 91
Mixture, 91
MCNP6.2, 91
Materials, 101, 125
Modular, 101, 107, 117
Molybdenum, 101
Monte, 101
Machine, 107
Mastery, 107
Measured, 107
Multiaxial, 125

N

Neutron, 91
Nuclear, 91, 125
Non-lead, 101

O

Outward, 91
Oxide, 101
Operator, 107

P

Performed, 91
Plant, 91, 117
Potential, 91, 101
Power, 91
Particle, 101
Properties, 101
Pure, 101
Protection, 117
PPS, 117
Phase, 117
Production, 125
PWR, 125

R

Reactor, 91, 107, 117, 125
Rate, 107
Radiation, 91, 101
Reaction, 107
Regulation, 107
Research, 107, 125
Recommendation, 107
RPS, 117
Reliability, 117
Role, 117
Reliability, 125

S

Safety, 91, 107
Salt, 91
Spent, 91
SNF, 91
Study, 91
Shielding, 101
Simulation, 101, 107
Simulator, 107
Substitutes, 101
System, 101, 125
SMR, 117
Secondary, 125
Structure, 125

T

Thickness, 91
Transmutation, 91
Transuranic, 91
TRU, 91
Transport, 91
Toxic, 101
Tracking, 101
Trioxide, 101
Tungsten, 101
Technology, 107

U

Utilization, 107

V

Vital, 125
Volatile, 125

W

Water, 125



Jurnal Teknologi Reaktor Nuklir

Tri Dasa Mega

Journal homepage: jurnal.batan.go.id/index.php/tridam

Author Index

	HALAMAN
Adhika Enggar Pamungkas.....	107
Ahmad Muzaki Mabruki	101
Almira Citra Amelia.....	107
Amar Vijai Nasrulloh	91
Andang Widi Harto	91
Adhika Enggar Pamungkas	91
Anik Purwaningsih.....	61, 107
Anis Rohanda	23, 45
Byan Wahyu Riyandwita	37
Dewi Nur Riskiana	37
Dhanu Dwiardhika	15
Dian Fitri Atmoko.....	99
Farisy Yogatama Sulistyو.....	15, 125
Fitria Miftasani.....	9
Gusti Atika Urfa.....	27
Hana Subhiyah.....	9
Hamdi Hamdi	51
Haryono Budi Santosa.....	61
Hendro Tjahjono	61
I Wayan Ngarayana....	23, 33
Ihda Husnayani	61
Iklimatul Karomah	85
Jupiter Sitorus Pane.....	61
Kiswanta	107
Lena Rosmayani	45
Muhammad Budi Setiawan.....	61
Muhammad Ridho	53
Muhammad Reza Maulana Aliva.....	69
Muhammad Subhan	15, 125
Muksin Aji Setiawan.....	107
Nuri Trianti.....	85
Pandhu Ardita Dharma Pratama.....	117
Prihadi Setyo Darmanto.....	1
Purwadi Purwadi	53

Purwo Kadarno	15
R Andika Putra Dwijayanto	91
Ratna Dewi Syarifah	85
Raden Farzand Abdullatif	23
R. Farzand Abdullatif.....	45
Raden Mohammad Subekti	1
Ratna Dewi Syarifah.....	85
Restu Maerani.....	59, 85
Sigit Santoso.....	107, 117
Sudarno.....	117
Soni Prayogi.....	9
Sri Hastuty.....	15
Sunny Ineza Putri.....	1
Tetti Novalina Manik.....	101
Theo Alvin Ryanto.....	61
Topan Setiadipura.....	15, 125
Totok Wianto.....	101
Tresna Priyana Soemardi.....	125
Tukiran Surbakti.....	53
Tulis Jojok Suryono.....	107, 117
Zainuddin Zainuddin.....	9



Jurnal Teknologi Reaktor Nuklir

Tri Dasa Mega

Journal homepage: jurnal.batan.go.id/index.php/tridam

Acknowledgment

The following Peer Reviewers:

- Prof. Drs. Surian Pinem MSi.
- Ir. Damianus Sony Tjahyani, M.Sc.
- Dr. Yus Rusdian Akhmad M.Eng.
- Dr. Julwan Hendry Purba S.T. M.App.IT.
- Dr. M. Budi Setiawan.
- Sofia Lorenz Butar Butar S.T, MSc.
- Dr. Kunihiko Nabeshima
- Ir. Ign. Djoko Irianto M.Eng.
- Dipl. Ing. (FH) Andi Sofrany Ekariansyah
- Dr. Mulya Juarsa, S.Si., MESC
- Restu Meirani S.T, MSc.
- Dr. Azizul Khakim MSc.

who have been involved in the reviewing of the articles in this issue of Tri Dasa Mega Vol. 25 No. 3 October 2023 are greatly acknowledged.